

1 BILL NO. S-82-05-24

2 SPECIAL ORDINANCE NO. S-104-82

3 AN ORDINANCE approving Change Order
4 No. 1 for 354-81, Sewage Metering
5 Facility, Washington Boulevard,
6 in connection with the Board of
7 Public Works

8 BE IT ORDAINED BY THE COMMON COUNCIL OF THE CITY
9 OF FORT WAYNE, INDIANA:


10 SECTION 1. That Change Order No. 1 for 354-81,
11 Sewage Metering Facility, Washington Boulevard to Earth Construct-
12 ion and Engineering, Inc. in connection with the Board of
13 Public Works, for:

14 a proposal by the contractor for a
15 prefabricated fast connection to the
16 east of the alley in lieu of utilizing
17 the existing manhole and wet conditions,
18 due to excessive flows in 21" sewer and
19 the risk of energy failure on long
20 term pumping,

21 causing no change in the contract price, as set out in the
22 specifications, which is on file in the Office of the Board of
23 Public Works, and is by reference incorporated herein, made a
24 part hereof, and is hereby in all things ratified, confirmed
25 and approved.

26 SECTION 2. That this Ordinance shall be in full
27 force and effect from and after its passage and approval by
28 the Mayor.

29 APPROVED AS TO FORM
30 AND LEGALITY

31 
32 Bruce O. Boxberger, City Attorney


Councilmember

Read the first time in full and on motion by Burns, seconded by Shaw, and duly adopted, read the second time by title and referred to the Committee City Utilities (and the City Plan Commission for recommendation) and Public Hearing to be held after due legal notice, at the Council Chambers, City-County Building, Fort Wayne, Indiana, on _____, 19____, at _____ o'clock _____ M., E.S.T.

DATE: 5-25-82

Charles W. Westerman
CHARLES W. WESTERMAN - CITY CLERK

Read the third time in full and on motion by Burns, seconded by Shaw, and duly adopted, placed on its passage. PASSED (~~Lost~~) by the following vote:

| | <u>AYES</u> | <u>NAYS</u> | <u>ABSTAINED</u> | <u>ABSENT</u> | <u>TO-WIT:</u> |
|--------------------|-------------|-------------|------------------|---------------|----------------|
| <u>TOTAL VOTES</u> | <u>8</u> | _____ | _____ | <u>1</u> | _____ |
| <u>BRADBURY</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>BURNS</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>EISBART</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>GIAQUINTA</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>NUCKOLS</u> | _____ | _____ | _____ | <u>X</u> | _____ |
| <u>SCHMIDT</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>SCHOMBURG</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>STIER</u> | <u>X</u> | _____ | _____ | _____ | _____ |
| <u>TALARICO</u> | <u>X</u> | _____ | _____ | _____ | _____ |

DATE: 6-8-82

Charles W. Westerman
CHARLES W. WESTERMAN - CITY CLERK

Passed and adopted by the Common Council of the City of Fort Wayne, Indiana, as (ZONING MAP) (GENERAL) (ANNEXATION) (SPECIAL)

(APPROPRIATION) ORDINANCE (RESOLUTION) NO. S-104-82
on the 8th day of June, 1982

ATTEST:

(SEAL)

Charles W. Westerman
CHARLES W. WESTERMAN - CITY CLERK

Samuel J. Talarico
PRESIDING OFFICER

Presented by me to the Mayor of the City of Fort Wayne, Indiana, on the 5th day of June, 1982, at the hour of 11:30 o'clock A. M., E.S.T.

Charles W. Westerman
CHARLES W. WESTERMAN - CITY CLERK

Approved and signed by me this 11th day of June, 1982, at the hour of 9 o'clock A. M., E.S.T.

Win Moses, Jr.
WIN MOSES, JR. - MAYOR

BILL NO. S-82-05-24

REPORT OF THE COMMITTEE ON CITY UTILITIES

WE, YOUR COMMITTEE ON City Utilities TO WHOM WAS REFERRED AN
ORDINANCE approving Change Order No. 1 for 354-81, Sewage Metering
Facility, Washington Boulevard, in connection with the Board of
Public Works

HAVE HAD SAID ORDINANCE UNDER CONSIDERATION AND BEG LEAVE TO REPORT
BACK TO THE COMMON COUNCIL THAT SAID ORDINANCE PASS.

PAUL M. BURNS - CHAIRMAN

MARK E. GIAQUINTA - VICE CHAIRMAN

JAMES S. STIER

JANET G. BRADBURY

ROY J. SCHOMBURG

CONCURRED IN

CHARLES W. WESTERMAN, CLERK

DATE

5682

TITLE OF ORDINANCE CHANGE ORDER #1, RES. 354-81, SEWAGE METERING DEVISE, Washington Blvd.

DEPARTMENT REQUESTING ORDINANCE Board of Public Works 1-82-05-24

SYNOPSIS OF ORDINANCE Due to excessive flows in 21" sewer and the risk of energy failure on long term pumping, the contractor has proposed a prefabricated fast connection to the east of the alley shown on the drawing in lieu of utilizing the existing manhole and wet conditions. Earth Construction & Engineering, Inc. is the contractor.

EFFECT OF PASSAGE better flow in sewer

EFFECT OF NON-PASSAGE congested sewer

MONEY INVOLVED (DIRECT COSTS, EXPENDITURE, SAVINGS) NO CHANGE IN PRICE

ASSIGNED TO COMMITTEE